



TACLA008546E

P.O. BOX 2461
1515 ARCHER CITY HWY.
WICHITA FALLS, TEXAS 76302



(940) 761-1808
(940) 538-5103
FAX (940) 766-1241

Montague County Jail
111 S Grand Street
Montague Texas

February 7, 2022

Office Area

Existing unit is 14 years old on R 22 refrigerant

Heat exchanger is bad. We recommend replacing the Unit.

Install new 7.5 ton Carrier rooftop unit

Includes all labor , materials and crane

5 year compressor warranty 10 year heat exchanger warranty

1 year parts and labor warranty

\$13,017.00

Trinity Air Conditioning

Lynn Robinson

ONE LESS THING TO WORRY ABOUT.™

Registered by the Texas Department of Licensing and Regulation • P.O. Box 12167 • Austin, TX 78711 • 800-453-6922